

Active Council Issues								
No.	Initiated	Research	Approval	Title	Description	Status / Actions	Opened	Targeted Close Date
UC67	OMO	UC	EC	Vacant UC position	The alternate Federal-Non DOD DOI position is vacant.	<b>23Apr18:</b> The OMO was informed that Mr. Kenneth Hallett is no longer working for the BLM. <b>16Jan20:</b> At the January 16 Executive Council meeting, Mr. Del Smith and ASAC Adam Pierce agreed to conduct a telephone call with the BLM to get an individual appointed.	23-Apr-18	30-Dec-18
UC76	OMO	UC	EC	Vacant UC position	The alternate SOA DPS position is vacant.	<b>31Jul19:</b> Mr. Leon Morgan was appointed as the new Deputy Commission for Public Safety leaving the alternate position vacant. <b>16Jan20:</b> At the January 16 Executive Council meeting, Deputy Commissioner Leon Morgan advised Mr. John Rockwell to appoint Captain Richard Roberts. <b>4Mar20:</b> Appointment letter designating Captain Richard Roberts as the new Alternate SOA DPS representative received.	31-Jul-19	CLOSED
UC77								
Active Operational Issues								
No.	Initiated	Research	Approval	Title	Description	Status / Actions	Opened	Targeted Close Date
OP05	OMO	OIT	UC	MW Refresh	Outages caused by MW bouncing (Glenn Hwy to Richardson Hwy)	<b>7Feb18:</b> Funds were identified to replace this string of legacy MW last last year. Request to purchase was denied. <b>6Feb19:</b> Funding for replacement is now in the procurement process. <b>4Nov19:</b> 55-hops of microwave has been procured and installation has begun at various sites throughout the system.	7-Feb-18	30-Dec-20
OP06	OMO	JBER	UC	R1 North	Rectifier issue	<b>11Mar19:</b> One of the six rectifiers at the R1 North site has failed. <b>26Mar19:</b> Per SSgt Paice, they are working to get quotes to get the battery banks and the rectifiers replaced.	11-Mar-19	30-Sep-19
OP07	OMO	SOA	UC	Quantars	Replacement of SOA Quantars	<b>12Mar19:</b> The ALMR System cannot go beyond the 7.17 software platform until the SOA completes the replacement of all of its Quantars.	12-Mar-19	31-Dec-20
OP08	OMO	USARAK	UC	Black Rapids	Battery plant failed testing	<b>3Apr19:</b> The SOA tested the battery plant at Black Rapids and found some of the battery cells are dead. Battery plant needs replaced. <b>7Aug19:</b> Mr. Williams stated Black Rapids was still being looked at; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.	3-Apr-19	31-Dec-19
OP10	OMO	USARAK	UC	Donnelly Dome rectifiers	Rectifier issue	<b>3Apr19:</b> The rectifiers at Donnelly Dome need to be replaced. They are the same make as the ones at Birch Hill. No spares available and no one will work on them. <b>7Aug19:</b> Mr. Williams stated Donnelly Dome needs a new DC power system; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.	3-Apr-19	31-Dec-19
OP12	OIT	Clear	UC	Clear	Microwave	<b>3Apr19:</b> The Clear microwave needs to be modernized	3-Apr-19	30-Jun-20
OP13								
Issues CLOSED at, or since, the last meeting								
OP02	OMO	USARAK	UC	Birch Hill Master Site	Four of eight rectifiers have failed.	CLOSED on February 10, 2020.		

**NOTE: Yellow highlight indicates change since last meeting**