

Active Council Issues								
No.	Initiated	Research	Approval	Title	Description	Status / Actions	Opened	Targeted Close Date
UC67	OMO	UC	EC	Vacant UC position	The alternate Federal-Non DOD DOI position is vacant.	<p>23Apr18: The OMO was informed that Mr. Kenneth Hallett is no longer working for the BLM.</p> <p>16Jan20: At the January 16 Executive Council meeting, Mr. Del Smith and ASAC Adam Pierce agreed to conduct a telephone call with the BLM to get an individual appointed.</p> <p>16Apr20: Contacted Mr. Willie Branson and sent copy of previous appointment letter so he could appoint Mr. Ross Atkinson.</p>	23-Apr-18	30-Dec-18
UC77								
Active Operational Issues								
No.	Initiated	Research	Approval	Title	Description	Status / Actions	Opened	Targeted Close Date
OP05	OMO	OIT	UC	MW Refresh	Outages caused by MW bouncing (Glenn Hwy to Richardson Hwy)	<p>7Feb18: Funds were identified to replace this string of legacy MW last last year. Request to purchase was denied.</p> <p>6Feb19: Funding for replacement is now in the procurement process.</p> <p>4Nov19: 55-hops of microwave has been procured and installation has begun at various sites throughout the system.</p> <p>1Jun20: UPDATE - The State is currently 45 percent complete with the installation to the microwave hopes</p>	7-Feb-18	30-Dec-20
OP06	OMO	JBER	UC	R1 North	Rectifier issue	<p>11Mar19: One of the six rectifiers at the R1 North site has failed.</p> <p>26Mar19: Per SSgt Paice, they are working to get quotes to get the battery banks and the rectifiers replaced.</p>	11-Mar-19	30-Sep-19
OP07	OMO	SOA	UC	Quantars	Replacement of SOA Quantars	<p>12Mar19: The ALMR System cannot go beyond the 7.17 software platform until the SOA completes the replacement of all of its Quantars.</p> <p>Apr20: The SOA approved a supplemental budget fully funding the replacement of their Quantars.</p>	12-Mar-19	CLOSED
OP08	OMO	USARAK	UC	Black Rapids	Battery plant failed testing	<p>3Apr19: The SOA tested the battery plant at Black Rapids and found some of the battery cells are dead. Battery plant needs replaced.</p> <p>7Aug19: Mr. Williams stated Black Rapids was still being looked at; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.</p>	3-Apr-19	31-Dec-19
OP10	OMO	USARAK	UC	Donnelly Dome rectifiers	Rectifier issue	<p>3Apr19: The rectifiers at Donnelly Dome need to be replaced. They are the same make as the ones at Birch Hill. No spares available and no one will work on them.</p> <p>7Aug19: Mr. Williams stated Donnelly Dome needs a new DC power system; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.</p>	3-Apr-19	31-Dec-19
OP12	OIT	Clear	UC	Clear	Microwave	<p>3Apr19: The Clear microwave needs to be modernized</p>	3-Apr-19	30-Jun-20
OP13	OIT	USARAK	UC	Birch Hill Master Site	UPS Side A failed	<p>2Apr20: Power outage at the Birch Hill Master Site occurred on March 11 around 3:00am. The technicians found that UPS 01 failed and was not passing power to the equipment on the ALMR "A" side power. They put the UPS in bypass to restore power to the equipment and called the power contractor on base to get an emergency ticket opened. Currently UPS 01 is still in bypass, so it is running on AC and has no back up power.</p> <p>11May20: This week Fort Wainwright DPW (BSTS) replaced the batteries in AC UPS #1 at the Birch Hill master site, which had been failing coming out of bypass mode during power failures. On Monday, May 18, the new batteries were fully charged and we took it out of bypass mode without incident. The effectiveness of the battery swap will not be seen until we experience power outages again.</p>	2-Apr-20	CLOSED
Issues CLOSED at, or since, the last meeting								

NOTE: Yellow highlight indicates change since last meeting