



ALMR User Council
Active Issues and Risks Log

Active Council Issues								
No.	Initiated	Research	Approval	Title	Description	Status / Actions	Opened	Targeted Close Date
UC79	OMO	UC	EC	Vacant UC position	The primary Municipalities North UC position is vacant	4/8/21: Assistant Chief Doug Fournier informed the OMO he was leaving his job position at the end of April, and would no longer be able to continue serving on the User Council as a Municipalities North Representative.	8-Apr-21	31-Oct-21
UC80								
Active Operational Issues								
No.	Initiated	Research	Approval	Title	Description	Status / Actions	Opened	Targeted Close Date
OP05	OMO	OIT	UC	MW Refresh	Outages caused by MW bouncing (Glenn Hwy to Richardson Hwy)	7Feb18: Funds were identified to replace this string of legacy MW last last year. Request to purchase was denied. 6Feb19: Funding for replacement is now in the procurement process. 4Nov19: 55-hops of microwave has been procured and installation has begun at various sites throughout the system. 1Jun20: UPDATE - The State is currently 45 percent complete with the installation fo the microwave hops. 22Sep20: UPDATE - The State is currently 85 percent complete with the upgrade to the microwave hops.	7-Feb-18	30-Dec-20
OP06	OMO	JBER	UC	R1 North	Rectifier issue	11Mar19: One of the six rectifiers at the R1 North site has failed. 26Mar19: Per SSgt Paice, they are working to get quotes to get the battery banks and the rectifiers replaced.	11-Mar-19	30-Sep-19
OP08	OMO	USARAK	UC	Black Rapids	Battery plant failed testing	3Apr19: The SOA tested the battery plant at Black Rapids and found some of the battery cells are dead. Battery plant needs replaced. 7Aug19: Mr. Williams stated Black Rapids was still being looked at; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.	3-Apr-19	CLOSED
OP10	OMO	USARAK	UC	Donnelly Dome rectifiers	Rectifier issue	3Apr19: The rectifiers at Donnelly Dome need to be replaced. They are the same make as the ones at Birch Hill. No spares available and no one will work on them. 7Aug19: Mr. Williams stated Donnelly Dome needs a new DC power system; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.	3-Apr-19	CLOSED
OP12	OIT	Clear	UC	Clear	Microwave	3Apr19: The Clear microwave needs to be modernized	3-Apr-19	30-Jun-20
OP13	OMO	JBER	UC	All DOD Microwave	DOD Microwave hops at EOL	8Jun20: The R1 North microwave was bouncing on June 5. It is stablized for the time being. All DOD microwave shots are at end of life and need to be modernized.	8-Jun-20	6-Jun-21
OP14								
Issues CLOSED at, or since, the last meeting								

NOTE: Yellow highlight indicates change since last meeting